

# VOC Content Test Certificate

Wednesday May 21<sup>st</sup>, 2008

Manufacturer: Waterproofing Technologies Pty Ltd

295 Princes Highway



St Peters NSW 2044

Sample Description: Enviro HP 1200 solvent free two -part polyurethane waterproofing membrane

Date Tested: May 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b>  <b>Green Star Office Design V2 IEQ-13</b>  <b>Green Star Office Design V3 IEQ-13</b>  <b>Green Star Office Interiors V1.1 IEQ-11</b>	 <b>HP 1200</b>  
Architectural Sealant 250 grams per Litre	<b>21 grams per Litre</b>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

F0805-58