

# VOC Content Test Certificate

Monday April 11<sup>th</sup>, 2011

Manufacturer: Waterproofing Technologies Pty Ltd


295 Princes Highway

St Peters NSW 2044

Sample Description: Enviro Shield water-based epoxy coating and membrane

Date Tested: November - December 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168 Test Data:

<p style="text-align: center;"><b>Specification</b></p> <p><b>Green Building Council of Australia</b></p> <p><b>Green Star Office Design V2 IEQ-13</b></p> <p><b>Green Star Office Interiors V1.1 IEQ-11</b></p>	 <p style="text-align: right;"><b>Shield</b></p> <p><b>enviro@systems</b></p>
<p>Architectural Sealant 250 grams per Litre</p>	<p style="text-align: center;"><b>72 grams per Litre</b></p>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

**Project F0711-10a**