

VOC Content Test Certificate

Friday December 7th, 2007

Manufacturer: Waterproofing Technologies Pty Ltd

295 Princes Highway


St Peters NSW 2044

Sample Description: Enviro 700 Pur single component high performance polyurethane membrane

Date Tested: November - December 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Office Design V2 IEQ-13</p> <p>Green Star Office Interiors V1.1 IEQ-11</p>	 <p>700 Pur</p> <p>enviro@systems</p>
<p>Architectural Sealant 250 grams per Litre</p>	<p>112 grams per Litre</p>



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

Project F0711-10