

VOC Content Test Certificate

Wednesday May 21st, 2008

Manufacturer: Waterproofing Technologies Pty Ltd

295 Princes Highway



St Peters NSW 2044

Sample Description: Enviro Imper bitumen modified waterproofing sheet

Date Tested: May 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Office Design V2 IEQ -13</p> <p>Green Star Office Design V3 IEQ -13</p> <p>Green Star Office Interiors V1.1 IEQ -11</p>	 <p>Imper</p> 
<p>Architectural Sealant 250 grams per Litre</p>	<p>15 grams per Litre</p>



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0805-58