

VOC Content Test Certificate

Friday, January 7th, 2011

Manufacturer: Waterproofing Technologies Pty Ltd (295-305 Princes Hwy, St Peters, NSW, 2044)

Sample Description: CemFlex

Tested: December 2010

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Cemflex
Architectural Sealant 250 grams per Litre as VOC content material	27 grams per Litre as VOC content material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	CemFlex
Architectural Sealant 250 grams per Litre as VOC content material	27 grams per Litre as VOC content material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1012-07