

VOC Content Test Certificate

Friday, January 7th, 2011

Manufacturer: Waterproofing Technologies Pty Ltd (295-305 Princes Hwy, St Peters, NSW, 2044)

Sample Description: PrimeME

Tested: December 2010

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	PrimeME
Timber and binding primers 30 grams per Litre as VOC content material	5 grams per Litre as VOC content material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	PrimeME
Timber and binding primers 30 grams per Litre as VOC content material	5 grams per Litre as VOC content material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1012-07