

# VOC Content Test Certificate

Friday December 7<sup>th</sup>, 2007

Manufacturer: Waterproofing Technologies Pty Ltd

295 Princes Highway


St Peters NSW 2044

Sample Description: Enviro Flex two-part reinforced waterproofing membrane

Date Tested: November - December 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p><b>Specification</b></p> <p><b>Green Building Council of Australia</b></p> <p><b>Green Star Office Design V2 IEQ-13</b></p> <p><b>Green Star Office Interiors V1.1 IEQ-11</b></p>	 <p><b>Flex</b></p> <p>enviro<b>systems</b></p>
<p>Architectural Sealant 250 grams per Litre</p>	<p><b>72 grams per Litre</b></p>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

**Project F0711-10**