

# VOC Content Test Certificate

Friday, January 7<sup>th</sup>, 2011

Manufacturer: Waterproofing Technologies Pty Ltd (295-305 Princes Hwy, St Peters, NSW, 2044)

Sample Description: Enviro 800PUR T.C

Tested: December 2010

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b>	<b>Enviro 800PUR T.C</b>
Architectural Sealant 250 grams per Litre as VOC content material	<b>200 grams per Litre as VOC content material</b>
<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	<b>Enviro 800PUR T.C</b>
Architectural Sealant 250 grams per Litre as VOC content material	<b>200 grams per Litre as VOC content material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

**F1012-24**